

PAS24:2022 - Enhanced Security Performance Requirements for Doorsets and Windows in the UK

Aanco (UK) Ltd t/a Made For Trade

Test Report No. R4791738076-2

24 June 2025



Table of contents

Table of contents..... 1

1. Introduction2

2. Summary of Results4

3. Description of Test Sample5



4. Test Arrangement.....8

5. Test Procedures9

6. Test Results..... 10

7. System Drawings..... 12

1. Introduction

Test Details	
Customer:	Aanco (UK) Ltd t/a Made For Trade Wellington House, Wynyard Avenue Billingham, TS22 5TB GB
Product tested:	Korniche FlatLite
Date(s) sample(s) received:	10 th April 2025
Date of test:	11 th April 2025
Test conducted at:	UL International (UK) Limited Halesfield 2 Telford Shropshire TF7 4QH
Test conducted by:	C Holden <i>Senior Laboratory Technician</i>
Report Authorisation	
Report compiled by:	E Round <i>Laboratory Engineer</i> 
Authorised by:	J Ratcliffe <i>Laboratory Engineer</i> 



UL International (UK) Limited, Unit 1-3 Horizon, Kingsland Business Park, Wade Road, Basingstoke, Hampshire RG24 8AH, is accredited by the United Kingdom Accreditation Service as UKAS Testing Laboratory No. 5772.

REPRODUCTION OF THIS DOCUMENT IN WHOLE OR ANY PART THEREOF MUST NOT BE MADE WITHOUT PRIOR WRITTEN PERMISSION FROM UL INTERNATIONAL (UK) LIMITED.

This report and the results shown within are based upon the information, drawings, samples and tests referred to in the report. The results obtained only apply to the sample tested and do not necessarily relate to samples from the production line of the above-named company and in no way constitute any form of representation or warranty as to the performance or quality of any products supplied or to be supplied by them. UL International (UK) Limited or its employees accept no liability for any damages, charges, cost or expenses in respect of or in relation to any damage to any property or other loss whatsoever arising either directly or indirectly from the use of the report.

UL International (UK) Telford Laboratory is authorised to act as a UK Approved/Notified Laboratory n. 0843 under the UKCA system and Northern Ireland provisions for the activities covered by this Report according to EN 13830:2003. The Approved/Notified Body number shall be used only when and, in the manner, authorized by the Approved/Notified Body. The Customer agrees that the Approved/Notified Body shall retain the right to control the use of the Report and Approved/Notified Laboratory number. If copies of Report documentation are provided to others it shall be reproduced in their entirety. Customer agrees that the promotion of its product utilizing the name, Report, or Approved/Notified Laboratory number of UL would mislead the public if such product is not covered by a Report issued by the Notified Laboratory; does not comply with the Applicable Requirements and applicable laws, regulations, and standards; or is used in any way not authorised by UL.

2. Summary of Results

The following table summarises the results of tests, conducted in accordance with PAS24:2022, achieved by the test specimen(s) supplied:

Test Description	Sample Tested (ID No.)	Test Sheet reference	Result	Test Date
C.4.4.2 – Infill manual test	1	TS 001	Pass	14 th April 2025
C.4.4.3 – Infill mechanical test	1	TS 001	Pass	14 th April 2025
Overall classification in accordance with PAS24:2022			W	

More comprehensive details are reported in section 6.

Note: *These results are valid only for the conditions under which the test was conducted.*

All measurement devices, instruments and other relevant equipment were calibrated and traceable to National Standards.

2.1 Decision rule

Classifications reported in section 6 indicate that the product conforms with the relevant accuracy requirements of section B.3 and C.3 of PAS24:2022.

2.2 Measurement uncertainty

The results as reported in this test report are not accounting measurement of uncertainty as no numerical values were recorded during the test.